

Watkins Glen Central School District
303 12th St.
Watkins, NY 14891

Gregory K. Kelahan
Superintendent of Schools
(607)535-3220
(607)535-4629 – fax



Dan DeLano
Director of Facilities II
(607)535-3271
(607)535-6023 - fax

February 18, 2020

Dear Watkins Glen School Community Members,

To protect public health, the Public Health Law and New York State Health Department (NYSDOH) regulations require all public schools and boards of cooperative educational services (BOCES) test lead levels in water from every cold water outlet being used, or could potentially be used, for drinking or cooking. If lead is found at any water outlet at levels above 15 parts per billion (ppb), which is equal to 15 micrograms per liter ($\mu\text{g}/\text{L}$), the NYSDOH requires that the school take action to reduce the level of lead.

We are pleased, during recent testing of our Elementary School, Field House and High School all sampling had levels below the 15 ppb action trigger.

If you have questions or wish to view a copy of the district's water testing results, please contact my office at (607-535-3271).

Sincerely,

Dan DeLano
Director of Facilities II
Watkins Glen Central School District

"Watkins Glen: From Ingenuity Comes Triumph."

Action Trigger above 15 (ppb)

Sample ID	Sample Location	Result (ppb)
E407-S	Rm 407-Sink	3
E412-S	Rm 412-Sink	4
E414-S	Rm 414-Sink	<1
E414-WF	Rm 414-WF	<1
E415-S	Rm 415-Sink	<1
E415-WF	Rm 415-WF	<1
E416-S	Rm 416-S	1
E416-WF	Rm 416-WF	<1
E417-S	Rm 417-Sink	<1
E417-WF	Rm 417-WF	<1
E418-S	Rm 418-S	<1
E418-WF	Rm 418-WF	<1
E419-S1	Rm 419 -sink 1	1
E419-S2	Rm 419-Sink 2	2
E419-WF	Rm 419-WF	<1
EWF1	WF adj to aud	<1
E403-S	Rm 403-sink	3
E402-S	Rm 402-sink	<1
E421-S1	Rm 421-sink 1	<1
E421-S2	Rm 421-sink 2	1
EWF2	WF at corner by 429	<1
E429-S	Rm 429-Sink	2
E431-S	Rm431-sink	2
E433-S	Rm 433-Sink	4
E435-S	Rm 435-Sink	3
E437-S	Rm 437-Sink	3
E436-S	Rm 436-Sink	<1
E434-S	Rm 434-sink	1
E432-S	Rm 432-sink	1
E430-S	Rm 430-sink	2
E428-S	Rm 428-sink	2
E438-S	Rm 438-sink	6
E439-S	Rm 439-sink	2
E440-S	Rm 440-sink	3
E441-S	Rm 441-sink	2
EK-HS-1	kitchen hs 1	2
EK-HS-2	kitchen hs2	1
EKHS-3	kitchen hs 3	1

"Watkins Glen: From Ingenuity Comes Triumph."

EK-FPS	kitchen food prep sink	<1
EK-KT	kettle tap	1
EWf-3	WF adj to 449 (left)	<1
EWf-4	WF adj to 449 (right)	<1
EBF1	bottle filler 1 (right)	<1
E449-S	Rm 449-sink	<1
E454-S	Rm 454-sink	3
E456-S	Rm 456-sink	<1
E456-WF	Rm 456-WF	<1
E457-S	Rm 457-sink	<1
E457-WF	Rm 457-WF	<1
E458-S	Rm 458-sink	<1
E458-WF	Rm 458-WF	<1
E459-S	Rm 459-sink	<1
E459-WF	Rm 459-WF	<1
E461-S	Rm 461-sink	4
E461-WF	Rm 461-WF	<1
E463-S	Rm 463-sink	<1
E463-WF	Rm 463-WF	<1
E465-S	Rm 465-sink	<1
E465-WF	Rm 465-WF	<1
E464-S	Rm 464-sink	<1
E464-WF	Rm 464-WF	<1
E462-S	Rm 462-sink	<1
E462-WF	Rm 462-WF	<1
E460-S	Rm 460-sink	<1
E460-WF	Rm 460-WF	<1
E455-S	Rm 455-sink	<1
E455-WF	Rm 455-WF	<1
E503-S	Rm 503-sink	4
E505-S	Rm 505-sink	5
E507-S	Rm 507-sink	4
E511-S	Rm 511-sink	6
E513-S	Rm 513-sink	5
E514-S	Rm 514-sink	4
E512-S	Rm 512-sink	6
E510-S	Rm 510-sink	4
EWf5	WF adj to 507	<1
E508-S	Rm 508-sink	7

"Watkins Glen: From Ingenuity Comes Triumph."

E506-S	Rm 506-sink	2
E504-S	Rm 504-sink	4
EWF6	WF adj to 502	<1
EBF2	Bottle filler 2 adj to 502	<1
WGE Total=80		

Sample ID	Sample Location	Result (ppb)
FH-WF1	adj to 618 storage towards gym	<1
FH-WF2	adj to 618 storage towards hall	<1
FH-WF3	adj to 601-1 storage	<1
FH-WF4	on hall closest to womens rm	<1
FH-WF5	on hall closest to mens rm	<1
FH-WF6	on hall closest to mens rm	<1
FH-BF1	bottle filler on WF6	<1
FH-WF7	adj to 601-2 storage towards gym	<1
FH-WF8	adj to 601-2 storage towards hall	<1
FH-IM	ice machine	<1
FH-WF9	WF towards field	<1
FH-WF10	WF towards gym	<1
FH-WF11	adj to storage 611	<1
FH-WF12	adj to field	<1
FH-WF13	adj to gym	<1
FH-WF14	adj to 634-upper deck	<1
FH-WF15	adj to 633-upper deck	<
WGFH		
Total=17		

Sample ID	Sample Location	Result (ppb)
HS-792-S	Rm792-sink	<1
HS-779-S1	Rm779-sink 1	1
HS-779-S2	Rm 779 sink 2	2
HS-779-S3	Rm 779 sink 3	2
HS-731-S1	Rm 731 sink 1	2
HS-731-S2	Rm 731 sink 2	1
HS-731-S3	Rm 731 sink 3	2
HS-731-S4	Rm 731 sink 4	2
HS-731-S5	Rm 731 sink 5	3

"Watkins Glen: From Ingenuity Comes Triumph."

HS-WF1	WF adj to rm 732	<1
HS-BF1	BF adj to 732	<1
HS-735-S	Rm 735 sink	<1
HS-734-S	Rm 734 sink	4
HS-749-S	Rm 749 sink	12
HS-700-S	Rm 700 music suite sink	3
HS-700-WF1	Rm 700 WF closet to sink	3
HS-700-WF2	Rm 700 WF farthest from sink	1
HS-805-S	Rm 805 sink	1
HS-720WF	WF adj to 720	<1
HS-720BF	BF adj to 720	<1
HS-769-S	Rm 769 sink	<1
HS-WF2	adj to 770 (right)	<1
HS-WF3	adj to 770 (left)	<1
HS-WF4	adj to café (right)	<1
HS-WF5	adj to café (left)	<1
HS-K-HS1	kitchen hand sink 1	1
HS-K-HS2	kitchen hand sink 2	1
HS-K-HS3	kitchen hand sink 3	3
HS-K-HS4	kitchen hand sink 4	<1
HS-K-HS-5	kitchen hand sink 5	<1
HS-K-K1	kitchen kettle 1	8
HS-K-K2	kitchen kettle 2	<1
MS/HS		
total=32		

“Watkins Glen: From Ingenuity Comes Triumph.”